



UNITED STATES ENVIRONMENTAL PROTECTION AGENCY
WASHINGTON, D.C. 20460

APR 4 1983

Mr. Robert R. La Du
Vice President
Zebron^(R) Corporation
19723 S.W. Teton Avenue
P.O. Box 1149
Tualatin, Oregon 97062

RE: File Number 6-19AEB81

Dear Mr. La Du:

Based on information submitted, the product listed below is acceptable as a coating for potable water applications when used within the conditions stated below:

Product: Zebron^(R) Polyurethane Coating


- Conditions:
1. The product is properly applied according to the manufacturer's specifications.
 2. The product continues to meet the specifications of good manufacturing practices.
 3. After complete curing, the coating is thoroughly rinsed with potable water prior to being placed in service.

We would not anticipate any adverse health effects resulting from such use of this product assuming the product continues to meet the supplied specifications.

We are currently in the process of revising our evaluation procedures as outlined in the Federal Register, Vol. 44, No. 141, 42775-8, Friday, July 20, 1979. When these revisions are completed and the interim procedures are in place, all existing advisories will be periodically reviewed.

Our opinion concerning the safety of the product does not constitute an endorsement, nor does it relate to its effectiveness for the intended use. If this letter is to be used in any way, we require that it be quoted in its entirety.

Sincerely yours,



Hugh F. Hanson, P.E., Acting Chief
Additives Evaluation Branch
Criteria and Standards Division
Office of Drinking Water (WH-550)

cc: Regional Drinking Water Representatives
Holders of the Water Supply Guidance Series
Mr. John Trax, State Programs Division, ODW