



Certified Product Listing

For:

Drinking Water System Components - Health Effects

Company:

Zebron Corporation
1141 N Cosby Way
Unit J
Anaheim, CA 92806, United States

Plant Location:

Anaheim, CA, United States

Standards:

NSF/ANSI/CAN 61 - 2018

Certificate:

Issued Date: 05/02/2019

Material/Product:

Polyurethane Protective Coatings

Contact Temperature:

23 ± 2°C

Models:

Zebron 386/9000



Product certified to NSF/ANSI 372 conforms to the requirements for "Lead Free" plumbing products as defined by California, Vermont, Maryland and Louisiana state laws and by section 1417 of the US SDWA.



Material Characteristics:

Minimum pipe diameter (inches): 24

Maximum pipe surface area/volume ratio (sq in/L): 10.2

Minimum tank size (gallons): 500

Maximum tank surface area/volume ratio (sq in/L): 7.5

Maximum dry film thickness per coat (mils): 250

Number of coats: 1

Is additional coating required (e.g. top coat, primer, intermediate coat)? (Y/N): Refer to manufacturer instructions for details

Total cure time and temperature: 5 days @ 23°C

Mix ratio: 3:1 (Zebron 386:Activator 9000) by Volume

Is this paint/coating system intended to be applied to a pipe? (Y/N): Yes

(1) Certified for use on a new pipe? (Y/N): Yes

(2) Certified for use on a pipe intended for immediate return to service? (Y/N): No



Product certified to NSF/ANSI 372 conforms to the requirements for "Lead Free" plumbing products as defined by California, Vermont, Maryland and Louisiana state laws and by section 1417 of the US SDWA.