



Certified Product Listing

For:

Drinking Water System Components - Health Effects

Company:

Zebron Corporation
1141 N Cosby Way
Unit J
Anaheim, CA 92806, United States

Plant Location:

Anaheim, CA, United States

Standards:

NSF/ANSI/CAN 61 - 2018

Certificate:

Issued Date: 05/02/2019

Material/Product:

Zebron Low Temperature Epoxy Primer

Contact Temperature:

23 ± 2°C

Models:

ZLTE



Product certified to NSF/ANSI 372 conforms to the requirements for "Lead Free" plumbing products as defined by California, Vermont, Maryland and Louisiana state laws and by section 1417 of the US SDWA.



Material Characteristics:

Minimum pipe diameter (inches): 1.5

Maximum pipe surface area/volume ratio (sq in/L): 163 (1051.6 sq cm/L)

Minimum tank size (gallons): 5

Maximum tank surface area/volume ratio (sq in/L): 40.4 (260.6 sq cm/L)

Maximum dry film thickness per coat (mils): 20

Number of coats: 1

Is additional coating required (e.g. top coat, primer, intermediate coat)? (Y/N): Refer to manufacturer instructions for details

Highest recommended percentage of thinner: Up to 10%

Total cure time and temperature: 7 days @ 23°C

Shortest cure time between coats or layers: 30 min @ 23°C

Final cure time: 7 days @ 23°C

Mix ratio: 2:1 (A:B)

Is this paint/coating system intended to be applied to a pipe? (Y/N): Yes

(1) Certified for use on a new pipe? (Y/N): Yes

(2) Certified for use on a pipe intended for immediate return to service? (Y/N): Yes



Product certified to NSF/ANSI 372 conforms to the requirements for "Lead Free" plumbing products as defined by California, Vermont, Maryland and Louisiana state laws and by section 1417 of the US SDWA.